



DECLARATION OF PERFORMANCE (DoP)

in accordance with Annex III to Regulation (EU) no. 305/2011
(Construction Products Regulation)

FIRESAFE / FSA

DoP No: FS/PP/FSA – 30.07.2025

1. Unique identification of the product type:

FIRESAFE / FSA Firestop Acrylic for Penetration Seals and Linear Joint Seals.

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4): See batch number on product packaging or scan the QR code on the packaging for detailed information.

FIRESAFE / FSA is supplied in a 310 ml plastic cartridge. 300 and 600 ml aluminium sausage tube.

3. Intended use or uses of the construction product in accordance with the applicable harmonised technical specification:

3.1 The intended use of FIRESAFE / FSA is to maintain the fire resistance performance of plasterboard walls, masonry walls and floors. Fire sealing of service penetrations and linear joints in all types of construction included in **ETA 25/0233 Penetration Seals and ETA 25/0235 Linear Joint Seals**.

3.2 The use category for the FIRESAFE / FSA system is indoor use in the following conditions: relative humidity lower than 85 % RH, except for temperatures below 0 °C, and without exposure to rain or UV (TR 024, type Z₂).

3.3 The provisions contained in the Declaration of Performance are based on an assumed service life of FIRESAFE / FSA of 25 years: provided that all conditions in the manufacturer's data sheets and instructions for packaging, transportation, storage, installation, use and repair have been met. The indications given to the end user cannot be interpreted as a guarantee provided by the manufacturer, but must only be considered as an aid to choosing the right products in relation to the expected financially reasonable service life of the solution.

4. Name, registered trade name or registered trademark and contact address of the manufacturer as required pursuant to Article 11(5):

Firesafe AS
Robsrudskogen 15, 1470 Lørenskog
Postboks 6411 Etterstad, 0605 OSLO
Telephone: +47 22 72 20 20
www.firesafe.no

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):
Not relevant.

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
AVCP System 1.

7. In case of the Declaration of Performance concerning a construction product covered by a harmonised standard:
Not relevant.

8. In case of the Declaration of Performance concerning a construction product for which a European Technical Assessment has been issued:

This Declaration of Performance has been prepared in accordance with the guidelines contained in EAD 350454-00-1104.
ETA 25/0233 and ETA 25/0235 prepared by UL International BV, Notified Body 2821, Certificate of Performance no. 2821-CPR-0344.

9. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
Reaction to fire	Class E	EN 13501-1
Resistance to fire	ETA 25/0233 and ETA 25/0235	EN 13501-2
Air permeability	NPD	EN 1026
Water permeability	NPD	EAD 350454-00-1104, Annex C
Release of hazardous substances	IA1, S/W2	EOTA TR 034
Mechanical resistance and stability	NPD	EOTA TR 001
Resistance to shock/movement	NPD	EOTA TR 001
Adhesion	NPD	EOTA TR 001
Airborne sound insulation	Rs,w (C;Ctr)= 54 (-3 ; -10) dB. Tested 12 mm joint depth and 15 mm backing material	EN 10140-2
Impact sound insulation	NPD	EN 10140-3
Thermal properties	NPD	EN 12664, EN 12667 or EN 12939
Water vapour permeability	NPD	EN ISO 12572, EN 12086
Durability and usability	Z ₂	EOTA TR 024

NPD = No Performance Determined.

- 10. The performance of the product identified in points 1 and 2 is in conformity with the performance in point 9.**
This Declaration of Performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of Firesafe:

Pål Paulsen

Technical Department – Product Manager, Firestopping Products
FIRESAFE AS

